

RockDelta

EFiC

European Fire & Conductivity Laboratory



DANAK

Reg. no. 431

EU no. 1142

Date 2004-01-19

Page 1 of 2

Ref: MBa/MBa

RockDelta a/s
Hovedgaden 584
DK-2640 Hedehusene

Subject: RockDelta® product RDS 145 (29P): Reaction to Fire test results

The RockDelta® stone wool based product RDS 145 (29P) has November 2003 been tested according to the standards EN/ISO 1716:2002 "Determination of gross calorific value" and EN/ISO 1182:2002 "Non-combustibility test".

The test report RDQ-03-2262 issued 2003-11-26 concludes:

The product tested RDS 145 (29P) satisfies the criterion's mentioned in clause 10.8.1 in EN 13501-1 "Fire classification of construction products and building elements-Part1: Classification using test data from reaction to fire test" for being classified as:

Class A1

Yours sincerely

EFiC Laboratory

Martin Bagge

Manager, Testing & Quality

Hovedgaden 584, DK-2640 Hedehusene. Phone +45 4655 8251, Fax. +45 4656 1525. E-mail: EFiC@EFiC.dk